

CONFIRMATION

Byggvarubedömningen

Daloc Trädörr, Laminat/Målad/Fanér and Daloc Ståldörr Prelaq /Omålad /Laminatplåt /Målad /Målad ox-färg /Rostfri /Grundmålad

supplied by
Daloc AB

RISE Research Institutes of Sweden AB received from Daloc AB two samples of doors which are representative of the manufactured products. They have been emission tested in accordance with relevant test method (ISO 16000-9 with evaluation according to EN 16516), see test reports O100785-1285020-1-2, dated 2024-11-11 and O100785-1285020-3-2, dated 2024-10-28.

The test results of the tested product prove that the products qualify for the emission requirements of **Byggvarubedömningen** (version 7.4, 2024-09-02):

Compounds	Criteria Byggvaru- bedömningen ($\mu\text{g}/\text{m}^3$)	Test results Daloc Trädörr, Laminat/Målad/Fanér ($\mu\text{g}/\text{m}^3$)	Test results Daloc Ståldörr Prelaq /Omålad /Laminatplåt /Målad /Målad ox- färg /Rostfri /Grundmålad (mg/m^3)
TVOC	≤ 300	< 10	< 10
Single VOC ($\mu\text{g}/\text{m}^3$)	$\leq \text{EU-LCI}$	< EU-LCI	< EU-LCI
R value	≤ 1	0.02	< 0.01
Formaldehyde	< 60	< 5	< 5
Volatile carcinogens 1A+1B	< 1	< 1	< 1

RISE Research Institutes of Sweden AB
Chemistry and Applied Mechanics- Chemical Product Safety

Maria Rådemar

RISE Research Institutes of Sweden AB

Postal address
Box 857
SE-501 15 BORÅS
Sweden

Office location
Brinellgatan 4
SE-504 62 BORÅS

Phone / Fax / E-mail
+46 10 516 50 00
+46 33 13 55 02
info@ri.se

This document may not be reproduced other than in full,
except with the prior written approval of RISE.

Verification

Transaction 09222115557539123148

Document

1285020-1-2-5 Daloc Trä + Stål CONF BVB

Main document

1 page

Initiated on 2025-02-13 11:22:19 CET (+0100) by Maria Rådemar (MR)

Finalised on 2025-02-13 11:22:19 CET (+0100)

Signatories

Maria Rådemar (MR)

RISE Research Institutes of Sweden AB

Company reg. no. 556464-6874

maria.rademar@ri.se

Signed 2025-02-13 11:22:19 CET (+0100)

This verification was issued by Scrive. Information in italics has been safely verified by Scrive. For more information/evidence about this document see the concealed attachments. Use a PDF-reader such as Adobe Reader that can show concealed attachments to view the attachments. Please observe that if the document is printed, the integrity of such printed copy cannot be verified as per the below and that a basic print-out lacks the contents of the concealed attachments. The digital signature (electronic seal) ensures that the integrity of this document, including the concealed attachments, can be proven mathematically and independently of Scrive. For your convenience Scrive also provides a service that enables you to automatically verify the document's integrity at: <https://scrive.com/verify>

